
5850mm
2m
3300mm
Canopy cover
1.2m
Services DB
Lights switch
Battery bank #1
UPS #1
UPS #2
Battery bank #2
Florecent/LED light tube.
Florecent/LED light tube.
Florecent/LED light tube.
Florecent/LED light tube.
24000 BTU Intern al HVAC UNIT #1 Not on scale
24000 BTU Intern al HVAC UNIT #1 Not on scale
24000BTU Outisde HVAC UNIT #1 Not on scale
Canopy cover
24000BTU Outisde HVAC UNIT #1 Not on scale
DB#1
DB#2
Floor cut outs and entry +blank off plate
Reinforced wall to attached distribution boards(3m)
KSAT STORAGE CONTAINER
1.9
Canopy cover
Outisde HVAC UNIT #1 Not on scale
Outisde HVAC UNIT #2 Not on scale
De-hyrdator HA2
De-hyrdator HA2
Cool air circulation -Blown direction -still unobstructed
Cool air circulation -Blown direction -still unobstructed
Rack#B01
600mm X1200mm
Location A
850mm
Rack#02
1.6m
Rack#03
Rack#04
Rack#05
Location B
UPS
670mm
2400mm
Battery bank
600mm
1460mm
1670mm
KSAT
600mm X 800mm
KSAT
KSAT
DG#1
600mm X 1000mm
DG#2
DG#3
Space-x
900mm
Lights switch
Canopy cover
Power Busbar A and B Source