


2x MAGLOCK  
1x CARD/FACIAL READER AT 1400mm AFFL  
1x RED BREAK GLASS UNIT AT 1200mm AFFL  
1x GREEN BREAK GLASS UNIT AT 1200mm AFFL




1x CARD/FACIAL READER AT 1400mm AFFL

1 Detail A  
1 : 25

63mm ROUND BOX WITH  
25mm CONDUIT LINK TO UNSAFE SIDE


CONDUITS TO LINK TO PSU  
AND TRUNKING IN CEILING VOID



Level 0  
0

2 Detail A(Safe Side)  
1 : 25


1x 2x4 BOX FOR:  
1x CARD/FACIAL AT 1400mm AFFL



Level 0  
0

3 Detail A(Unsafe Side)  
1 : 25

1x MAGLOCK  
1x PUSH BUTTON AT 1400mm AFFL  
1x RED BREAK GLASS UNIT AT 1200mm AFFL  
1x GREEN BREAK GLASS UNIT AT 1200mm AFFL




1x CARD/FACIAL READER AT 1400mm AFFL

4 Detail B  
1 : 25

63mm ROUND BOX WITH  
25mm CONDUIT LINK TO UNSAFE SIDE


CONDUITS TO LINK TO PSU  
AND TRUNKING IN CEILING VOID



Level 0  
0

5 Detail B(Safe Side)  
1 : 25


1x 2x4 BOX FOR:  
1x CARD/FACIAL AT 1400mm AFFL



Level 0  
0

6 Detail B(Unsafe Side)  
1 : 25

1x DOOR CONTROLLER AT 1400mm AFFL




1x CARD/FACIAL READER AT 1400mm AFFL

7 Detail C  
1 : 25

CONDUITS TO LINK TO PSU  
AND TRUNKING AT HIGH LEVEL

32A DP ISOLATOR

4x4 BOX FOR LINK TO DATA  
AND DOOR CONTROLLER



Level 0  
0

8 Detail C(Safe Side)  
1 : 25

4x4 BOX FOR LINK TO DATA  
AND DOOR CONTROLLER

25mm CONDUIT  
CHASED IN WALL

1x 2x4 BOX FOR DOOR  
CONTROLLER AT 1400mm AFFL  
1x 25mm CONDUIT LINK TO UNSAFE SIDE

1x CARD/FACIAL READER AT 1400mm AFFL

Level 0  
0

9 Detail C(Unsafe Side)  
1 : 25

FOR TENDER

- REVISIONS -			
REV	DATE	DESCRIPTION	SIGN
TD	2025-02-07	ISSUED FOR TENDER	S.P

- LEGEND -

- ELECTRICAL NOTES -

- ARCHITECT -



ARCH. REV.:

A



FOR TENDER

- PROJECT -

Project Name



APPROVED:	F.L.	PILOT DATE:	02/04/25
CHECKED:	F.L.	SCALE:	1 : 25
DESIGNED:	S.P.	DRIVE:	
DRAWN:	S.P.	FILE:	Project Name

- DRAWING DESCRIPTION -

Typical Access Control  
Details

- DRAWING NUMBER -

SMFN-CAI-EE-DR-008\_06

REV

TD