



- NOTES:
1. THIS SECTION FORMS PART OF A THREE COMPARTMENT DB
  2. ALL EARTH WIRE SHALL BE INSULATED

AS BUILT

DISTRIBUTION BOARD CONSTRUCTION						DISTRIBUTION BOARD ELECTRICAL SPECIFICATION							
RECESSED		LOCKABLE DOORS	<input checked="" type="checkbox"/>	COLOUR - MAIN	ELECTRIC ORANGE	WIDTH		BUSBAR RATING	200A	FRONT ACCESS	<input checked="" type="checkbox"/>	CABLE ENTRY: TOP	
HALF-RECESSED		SEPERATE DIVISIONS	<input checked="" type="checkbox"/>	COLOUR - EMERGENCY	RED	HEIGHT		FAULT LEVEL	5KA	REAR ACCESS	<input checked="" type="checkbox"/>	CABLE ENTRY: BOTTOM	
SURFACE		EMERGENCY SECTION	<input checked="" type="checkbox"/>	COLOUR - UPS	VERDIGRIS GREEN	DEPTH		FULL NEUTRAL	<input checked="" type="checkbox"/>	SUPPLY: SINGLE CORE	<input checked="" type="checkbox"/>	FUTURE EXPANSION	
FLOOR-STANDING		UPS SECTION	<input checked="" type="checkbox"/>	COLOUR - NORMAL	ELECTRIC ORANGE			HALF - NEUTRAL	<input checked="" type="checkbox"/>	SUPPLY: CABLE	<input checked="" type="checkbox"/>	CABLE ENTRY: REAR	
DOORS		NORMAL SECTION	<input checked="" type="checkbox"/>	SPARE SPACE	30 %			EQUIPMENT	MERLIN GERIN	SUPPLY: BUSBAR	<input checked="" type="checkbox"/>	FUTURE EXPANSION	

REVISIONS		BKS Inc./Ing		TITLE	
1	02/91	DELETED ISOLATION TRANSFORMER, FEED TO PP2- AREA 7. CHANGED CABLE AND MCB SIZE TO PO/1	CONS. NO. BKS-4771/232/ZE/033		REV. Z
			SCALE N. T. S.		
			DATE SEPT 1990		
NO.	DATE	DESCRIPTION	DESIGNED H. P. M.	DRAWN H. B/CAD	CHECKED H. P. M.

SCHEMATIC - GROUND FLOOR DB 232/MAIN/C (CLEAN)	
DWG. NO. 671/000 2443	REV. Z